

TEST AND RANGE CLASSIFICATION SIMPLIFIED REPORT

REPORT Nº : P-21-23392/5/I

GAIKER Foundation notifies that the matt white paints range supplied for testing by:

INDUSTRIAS JUNO, S.A. Barrio Saconi, 10, 48950 Erandio (BIZKAIA)

with range trade reference:

MATT WHITE PAINTS INCLUDING THE REFERENCES: PLÁSTICA EXTRAMATE J-33 OPAK I-500

Obtains the following classification a/t EN 13501-1:2018 for the field of application defined for the range (*)

Fire behavior		Smoke production		Flaming droplets
B	-	s1	,	d0

(*) Classification valid for the product range: i) applied in the quantity of approximately 300-320 g of liquid plastic paint/m² (equivalent to 90 microns) ii) applied on any metallic substrate or on any substrate showing A2-s1, d0 reaction to fire Euroclassification (fibre cement, calcium silicate board or gypsum plasterboard type) showing a density equal to or higher than 525 kg/m³ and iii) tested the whole, the plastic paint applied on gypsum plasterboard, directly supported on calcium silicate boards.

This classification is the result of the data included in the test reports P-21-23392/1/I, P-21-23392/2/I and P-21-23392/3/I and in the range classification report P-21-23392/4/I, all of them made by GAIKER between 07th/07/2021 and 15th/07/2021.

This report is a translation of the original P-21-23392/5 in Spanish. In case any conflict arises, the Spanish version will prevail.