

TEST AND RANGE CLASSIFICATION SIMPLIFIED REPORT

REPORT Nº : P-23-25916/5/I

GAIKER Foundation notifies that the enamels range supplied for testing by:

INDUSTRIAS JUNO, S.A.

Barrio Saconi, 10, 48950 Erandio (BIZKAIA)

with range trade reference:

WATER BASED ENAMELS WATERPLUS AND ACUNOX/ESMALSHIELD

Obtains the following classification a/t EN 13501-1:2018 for the field of application defined for the range (*)

Fire behavior		Smoke production		Flaming droplets
C	-	s2	,	d0

(*) Classification valid for the product range: i) applied in the quantity of approximately 200-210 g of liquid enamel/m² (equivalent to 60 microns), ii) applied on flame retarded MDF board substrate 15 mm thick and EUROCLASS B-s1, d0 and iii) tested the whole, the enamel applied on the flame retarded MDF board substrate, supported directly on calcium silicate boards

This classification is the result of the data included in the test reports P-23-25916/1/I, P-23-25916/2/I and P-23-25916/3/I and in the range classification report P-23-25916/4/I, all of them made by GAIKER between 09th/01/2024 and 24th/01/2024.

This report is a translation of the original P-23-25916/5 in Spanish. In case any conflict arises, the Spanish version will prevail.

Classification obtained following the simple binary acceptance decision rule. This decision rule, according to ILAC-G8:09 guide, leads to the following specific risk: probability of false acceptance or probability of false rejection is less than 50%.